

## DECLARATION OF PERFORMANCE No. DoP14021301

- 1. Unique identification code of the product-type: EA-323-2
- Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

EA-323-2 and serial number of each production lot are indicated in the label on the bottom case of the products.

- Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:
  Fire detection and alarm systems installed in buildings
- 4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Registered trade mark: Everday

Registered trade name and contact address: Everday Technology Co., Ltd. No. 95, Sec. 2, Ligong 1<sup>st</sup> Rd., Letzer Industrial Park, Yilan County 26841, Taiwan are indicated in the label on bottom case of the products

- Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):
   N/A
- System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:
   System 1+
  - In case of the declaration of performance concerning a construction product covered by a harmonized standard: LPCB, UKAS Testing 0758

Performed EN54-5:2000+A1:2002 under System 1+ and issued Certificate No. 512d

8. In case of the declaration of performance concerning a construction product for which a European Technical

Assessment has been issued:

## Not applicable see item 7

## 9. Declared performance

All requirements including all Essential Characteristic and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN mentioned in the table below.

Harmonized technical specification		EN-54-4:2000+A1:2002
Essential characteristic	performance	Clause
Nominal activation conditions / sensitivity / Response delay (response time) and performance under fire conditions	Pass	5.2, 5.3, 5.4, 5.5, 5.6, 5.8
Operational reliability	Pass	4.1, 4.4, 4.5, 4.11, 4.9, 4.10, 5.15, 5.14
Tolerance to supply voltage	Pass	5.7
Durability of operational reliability and response delay, temperature resistance	Pass	5.9, 5.10
Durability of operational reliability, vibration resistance	Pass	5.16, 5.17
Durability of operational reliability, humidity resistance	Pass	5.11, 5.12
Durability of operational reliability, corrosion resistance	Pass	5.13
Durability of operational reliability, electrical stability	Pass	5.18

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Monica Tsai / Sales Director l

Taiwan, Feb. 13, 2014